



CAL FIRE - Office of the State Fire Marshal Information Bulletin 21-002

Issued: May 7, 2021

Kidde Recalls TruSense Smoke and Combination Smoke/Carbon Monoxide Alarm (Model Series 2040, 2050, 2060, and 2070)

Model	Alarm	Key Feature
2040-DSR		
2050-DS10		
2060-ASR		
2070-VASR 2070-VDSR		
2070-VDSCR 2070-VASCR		

On May 6, 2021, fire safety products manufacturer Kidde recalled Model Series 2040, 2050, 2060, and 2070 Smoke and Combination Smoke/Carbon Monoxide Alarms due to risk of failure to alert consumers to a fire.

Only alarms with the TruSense logo or “AMBER=FAULT” printed on the front of the alarm are included in this recall. The model number is printed on the back of the alarm.

The recalled units are the following:

Models	Alarm Type	CSFM Listing No.
2040-DSR	Smoke	Not listed in California
2050-DS10	Smoke	7257-1610:0512
2060-ASR	Smoke	7257-1610:0513
2070-VDSCR	Combination Smoke/Carbon Monoxide	Not listed in California
2070-VASCR	Combination Smoke/Carbon Monoxide	7263-1610:0509
2070-VDSR	Smoke	Not listed in California
2070-VASR	Smoke	7257-1610:0508

Consumers should immediately contact Kidde for a free replacement alarm. Consumers should keep using the recalled alarms until they install replacement alarms.

Additional information on the Kidde TruSense Smoke and Combination Smoke/Carbon Monoxide Alarm recall from the US Consumer Product Safety Commission:

<https://www.cpsc.gov/Recalls/2021/Kidde-Recalls-TruSense-Smoke-and-Combination-Smoke-Carbon-Monoxide-Alarms-Due-to-Risk-of-Failure-to-Alert-Consumers-to-a-Fire>